



## Inspection Report

---

STONY BROOK UNIVERSITY

Customer ID: 298

Certificate: 21-R-0039

Site: 001

DIV. OF LAB ANIMAL RESOURCES

BST, LEVEL 1 ROOM 223 DIV OF LAB ANIMAL RSRC

Type: ROUTINE INSPECTION

STONY BROOK, NY 11794

Date: Jun-07-2010

---

This was focused inspection to review the items of personnel qualifications and veterinary care that were cited on the inspection of Jan 2010

Facility is in compliance with respect to those issues . Facility is reminded that it is still responsible for the correction of any and all other issues cited on the previous report on In Jan 2010.

An exit briefing took place at the end of this inspection

---

**Prepared By:**

JOHN LOPINTO, D V M                      USDA, APHIS, Animal Care

**Date:**

**Title:** VETERINARY MEDICAL OFFICER Inspector 1008

Jun-07-2010

**Received By:**

(b)(6), (b)(7)(c)

**Date:**

**Title:**

Jun-09-2010



## Inspection Report

STONY BROOK UNIVERSITY

Customer ID: 298

Certificate: 21-R-0039

Site: 001

BST, LEVEL 1 ROOM 223 DIV OF LAB ANIMAL

DIV. OF LAB ANIMAL RESOURCES

Type: ROUTINE INSPECTION

Date: Jan-07-2010

STONY BROOK, NY 11794

### 2.32 (c) (3)

#### PERSONNEL QUALIFICATIONS.

Item Personnel Qualifications 2.32 c 3

Training and instruction of personnel must include guidance in the proper use of anesthetics, analgesics and tranquilizers for any species used in the facility.

In reviewing records at this facility it was discovered that on 6/16/09 due to improperly connected anesthetic hoses an animal died.

Facility redeveloped its procedures and included a checklist to be followed prior to any surgery. A review of further surgical cases since June of 09 shows no further incidents.

Facility needs to continue to monitor and insure personnel are trained and qualified in anesthesia and monitoring.  
Corrected at time of inspection.

### 2.33 (b)

#### ATTENDING VETERINARIAN AND ADEQUATE VETERINARY CARE.

Item Veterinary Care 2.33b

Each research facility shall maintain a program of adequate veterinary care.

The investigator for protocol 1507 indicates that anesthesia will be monitored by heart rate, respiratory rate and response to noxious stimuli.

In reviewing surgical records they only indicate the level of isoflurane, there is no other documentation of monitoring.

Facility needs to insure animals are monitored as indicated in the protocol.

Correct from this day.

### 3.56 (c)

#### SANITATION.

Item Housekeeping 3.56c

Premises shall be kept clean and in good repair to facilitate good husbandry practices.

Area in the Ceiling in cage washer area of the Life Sci bldg is peeling .

#### Prepared By:

JOHN LOPINTO, D V M USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1008

Jan-07-2010

#### Received By:

(b)(6), (b)(7)(c)

Date:

Title:

Jan-07-2010



## Inspection Report

---

Corridor ceiling outside room 211-F is peeling  
Facility needs to repair area .

Correct by 3/1/10

**3.84** (c)

### CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.

Item Housekeeping 3.84c

Premises shall be kept clean and in good repair to facilitate good husbandry practices.

Refrigerator in Computer Sci bldg has areas of rust and needs to be cleaned.

Facility needs to clean areas of rust.

Correct by 1/21/10

**3.131** (c)

### SANITATION.

Item Housekeeping 3.131c

Premises shall be kept clean and in good repair to facilitate good husbandry practices.

The enrichment room in the Health Sci center bldg has an area of the ceiling cracking and needs to be repaired.

Facility needs to repair ceiling.

Correct by 3/1/10

Inspection took place over 2 days 1/6-7/10

---

**Prepared By:**

JOHN LOPINTO, D V M                      USDA, APHIS, Animal Care

**Date:**

**Title:** VETERINARY MEDICAL OFFICER Inspector 1008

Jan-07-2010

**Received By:**

(b)(6), (b)(7)(c)

**Date:**

**Title:**

Jan-07-2010



## Inspection Report

---

STONY BROOK UNIVERSITY

Customer ID: 298

Certificate: 21-R-0039

BST, LEVEL 1 ROOM 223 DIV OF LAB ANIMAL

Site: 001

DIV. OF LAB ANIMAL RESOURCES

Type: ROUTINE INSPECTION

STONY BROOK, NY 11794

Date: Apr-06-2009

---

### 3.56 (c)

#### SANITATION.

Item Housekeeping 3.56c

Premises shall be kept clean and in good repair to facilitate good husbandry practices.

Clean side of cage washer in Life Sci bldg is peeling and the air vent in the rabbit room dirty.

Facility needs to repair ceiling and clean air vent.

Correct by 5/10/09

### 3.80 (a) (1)

#### PRIMARY ENCLOSURES.

Item Primary Enclosures 3.80 a 1

Primary enclosures must be structurally sound and be kept in good repair

Transport cage used for Non-human primates has 2 panels with cracked plexi glass.

Facility needs to repair/replace transport cage.

Correct by 4/10/09

### 3.84 (c)

#### CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.

Item Housekeeping 3.84 c

Premises shall be kept clean and in good repair to facilitate good husbandry practices.

Loading dock in Computer Sci bldg has an accumulation of boxes, chairs and other debris gong into the facility.

Facility needs to insure debris is removed in timely manner to maintain good housekeeping.

Correct by 4/10/09

---

#### Prepared By:

JOHN LOPINTO, D V M USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1008

Apr-06-2009

#### Received By:

(b)(6), (b)(7)(c)

Date:

Title:

Apr-06-2009



## Inspection Report

---

**3.131** (c)

**SANITATION.**

Item Housekeeping 3.131c

Premises shall be kept clean and in good repair to facilitate good husbandry practices

Surgery rm OR 3 has an area wall blistering that needs to be repaired.

Facility needs to repair wall surface.

Correct by 5/10/09

---

**Prepared By:**

JOHN LOPINTO, D V M                      USDA, APHIS, Animal Care

**Title:** VETERINARY MEDICAL OFFICER Inspector 1008

**Date:**

Apr-06-2009

**Received By:**

(b)(6), (b)(7)(c)

**Date:**

Apr-06-2009

**Title:**



## Inspection Report

STONY BROOK UNIVERSITY

Customer ID: 298

Certificate: 21-R-0039

Site: 001

DIV. OF LAB ANIMAL RESOURCES

BST, LEVEL 1 ROOM 223 DIV OF LAB ANIMAL RSRC

Type: ROUTINE INSPECTION

STONY BROOK, NY 11794

Date: Feb-05-2008

**2.31** (e) (4)

### INSTITUTIONAL ANIMAL CARE AND USE COMMITTEE (IACUC).

Item IACUC 2.31 e 4

The IACUC shall insure a protocol contains a description designed to assure that discomfort and pain to animals is limited to that which is unavoidable for the conduct of research including provision for the use of analgesic, anesthetic, and tranquilizing drugs where indicated.

For protocol 1496 the investigator indicates the use of buprenorphine two times a day but does not provide a time frame for the number of days of duration.

The IACUC shall insure the investigator provides a time frame for the duration of post-op analgesia.

Correct by 2/25/08

**2.36** (b) (3)

### ANNUAL REPORT.

Item Annual Report 2.36 b 3

The facility shall insure an annual report is submitted and that the facility is adhering to the standards and regulations under the act and that it has required that exceptions to the standards and regulations be specified and explained by the Principal investigator and approved by the IACUC and a summary of such exceptions be attached to the annual report.

At the time of inspection it was discovered that this facility had a protocol involving hamsters on circadian rhythms with an approved exception. The facility did not include this exception on the annual reports to the USDA for the last 2 years.

Facility needs to insure all exceptions are included in its annual report and submit a letter to USDA concerning its exceptions

correct from this day 2/5/08

Note facility is writing a letter concerning this at the time of inspection

**Prepared By:**

JOHN LOPINTO, D V M USDA, APHIS, Animal Care

**Date:**

**Title:** VETERINARY MEDICAL OFFICER Inspector 1008

Feb-05-2008

**Received By:**

(b)(6), (b)(7)(c)

**Date:**

**Title:**

Feb-05-2008



## Inspection Report

---

3.11 (c)

### CLEANING, SANITIZATION, HOUSEKEEPING, AND PEST CONTROL.

Item Housekeeping 3.11 c

Premises including buildings and surrounding grounds must be kept clean and in good repair to facilitate good husbandry practices

Ceiling in canine rm 62 has an area that is beginning to peel

Facility needs to repair surface in order to maintain good husbandry practices.

Correct by 2/28/08

3.56 (c)

### SANITATION.

Item Housekeeping 3.56c

Premises shall be kept clean and in good repair to facilitate good husbandry practices

Life Science building has a ceiling leak in the corridor east of rm 211-D

Facility needs to repair leak and repair corridor wall surface in order to maintain good husbandry practices

Correct by 4/1/08

Psy A building has door sweeps missing on doors leading from the loading dock into the building allowing the for entry debris and pests.

Computer Sci building has an accumulation of empty boxes and other debris on the loading dock entrance.

The above items need to be repaired/cleaned in order to maintain good husbandry practices

Correct 3/10/08

Inspection took place over 2 days Feb 4-5 2008

---

Prepared By:

JOHN LOPINTO, D V M                      USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1008

Feb-05-2008

Received By:

(b)(6), (b)(7)(c)

Date:

Title:

Feb-05-2008