



Inspection Report

UNIVERSITY OF WISCONSIN-OSHKOSH

Customer ID: **795**

Certificate: **35-R-0111**

Site: 001

800 ALGOMA BLVD

UNIVERSITY OF WISCONSIN-OSHKOSH

Type: ROUTINE INSPECTION

Date: May-20-2009

OSHKOSH, WI 54901

No non-compliant items identified during this inspection.

Inspection conducted with the IACUC Chair.

Prepared By:

DAWN E BARKSDALE, D V M USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1062

May-20-2009

Received By:

(b)(6), (b)(7)(c)

Date:

Title:

May-20-2009



Inspection Report

UNIVERSITY OF WISCONSIN-OSHKOSH

Customer ID: **795**

800 ALGOMA BLVD

Certificate: **35-R-0111**

Site: 001

UNIVERSITY OF WISCONSIN-

Type: ROUTINE INSPECTION

OSHKOSH, WI 54901

Date: May-21-2008

No non-compliant items identified during this inspection.

Inspection conducted with IACUC Chair, Attending Veterinarian and inspector of record.

Prepared By:

DAWN E BARKSDALE, D V M USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1062

May-21-2008

Received By:

(b)(6), (b)(7)(c)

Date:

Title:

May-21-2008



Inspection Report

UNIVERSITY OF WISCONSIN-OSHKOSH

Customer ID: 795

Certificate: 35-R-0111

Site: 001

UNIVERSITY OF WISCONSIN-OSHKOSH

800 ALGOMA BLVD

Type: ROUTINE INSPECTION

OSHKOSH, WI 54901

Date: Jun-01-2007

3.126 (a)

FACILITIES, INDOOR.

(a) Ambient temperatures. Temperature in indoor housing facilities shall be sufficiently regulated by heating or cooling to protect the animals from the extremes of temperature, to provide for their health and to prevent their discomfort. The ambient temperature shall not be allowed to fall below nor rise above temperatures compatible with the health and comfort of the animal.....

**While conducting the annual inspection this inspector was informed that on April 28, 2007 two 13-lined ground squirrels were found dead. Upon further investigation the following was noted:

-The principal investigator conducted a check at approximately 10:30 a.m.. Two young 13-lined ground squirrels were found dead in their enclosures.

-The temperature in the room registered 105 degrees and steam was seen coming into the room through the air vents.

-The cause of the rise in temperature was apparently a broken steam pipe.

-No back-up system was in place at the time. The facilities worker was contacted who turned off the steam to the building to prevent more heat from blasting into the room. Floor fans were placed in the room to help provide proper ventilation.

-The principal investigator was informed by facilities that no air conditioning was available on campus yet so fans would be the only form of ventilation.

-According to the principal investigator last July during 100 degree weather the facility temperature spiked to 88 degrees. Facilities management indicated that would not be a problem again because a second chiller would be added. As of this date, a second chiller has not been added.

The research facility should ensure that proper monitoring systems are in place to protect the health and well-being of the animals. The principal investigator has indicated that a temporary back-up system has been put in place that will trigger an alarm if the temperatures rise above acceptable levels.

Prepared By:

DAWN E BARKSDALE, D V M USDA, APHIS, Animal Care

Date:

Title: VETERINARY MEDICAL OFFICER Inspector 1062

Jun-01-2007

Received By:

(b)(6), (b)(7)(c)

Date:

Title:

Jun-12-2007



Inspection Report

Animals affected: (50)

Correct by August 1, 2007

Prepared By:

DAWN E BARKSDALE, D V M USDA, APHIS, Animal Care

Title: VETERINARY MEDICAL OFFICER Inspector 1062

Date:

Jun-01-2007

Received By:

(b)(6), (b)(7)(c)

Date:

Jun-12-2007

Title: